


Crown Point Central School

P.O. Box 35, 2758 Main Street
Crown Point, NY 12928
518-597-4200/3285 Fax 518-597-4121



Home of the Panthers

Shari L. Brannock
Superintendent

brannock@cpesteam.org

Tara Celotti
Principal PreK-12

tspaulding@cpesteam.org

Victoria D. Russell
District Treasurer

vrussell@cpesteam.org

Dear Parents and Staff Members:

On September 6, 2016, Governor Andrew Cuomo signed legislation requiring all school districts in New York State to test potable water systems for lead contamination and to take responsive actions. This law, and subsequent NYS Department of Health Regulations, required samples to be drawn from elementary schools on or before September 30, 2016.

Samples were collected at Crown Point Central School on September 23, 2016. Samples are required to be "first draw" samples, which requires that the water is motionless for at least eight (8) hours in the pipes and fixtures before it is collected. The level of lead concentration at a water outlet that requires us to take action is **above fifteen (15) parts per billion,ppb (0.015)**.

Test results that were received by the District on October 12th for the 75 outlets tested showed that four (4) outlets were above this action level. The locations, the concentration levels and our immediate action plan for the outlets is listed below. We will work with Department of Health officials to determine any retesting protocols we are required to put in place and we have arranged to replace the fixtures as soon as possible.

Please be assured that health and wellness is very important to us and that we will take all steps necessary to ensure that the water in our buildings is safe to drink.


In addition to this notification, test results will also be posted on our website, www.crownpointpanthers.org.


<u>Location</u>	<u>Concentration Level</u>	<u>Action</u>
Sink in Hall Bathroom	0.0176 ppb	Sink Labeled "Hand Washing Only -----Do Not Drink" <u>New fixture ordered</u>
Boys Home Dugout	0.0242 ppb	Sink Labeled "Out of Order, Do Not Use, Do Not Drink" <u>New fixture ordered</u>
Sink in Kitchen (middle)	0.201 ppb	Sink Labeled "Out of Order, Do Not Use, Do Not Drink" <u>New fixture ordered</u>
Girls Locker Room Fountain	0.0152 ppb	Fountain Taken Out of Service

The girls' locker room fountain is rarely, if ever, used. It has been taken out of service permanently as there is a new fountain that staff and students use nearby. The kitchen sink is not used for drinking and will not be used for cooking. As a side note, NYS set its own threshold at 15 parts per billion (0.015) that we must adhere to. The Environmental Protection Agency (EPA) guidelines has a 20 parts per billion (0.020) level. We would have had only 2 out of 75 outlets above the EPA threshold. All outlets will be remedied to meet NYS requirements.

If you have any questions regarding this process, please contact the main office or the Buildings and Grounds office at 597-3285.

Sincerely,


Shari L. Brannock
Superintendent of Schools


Caleb J. Spaulding
Buildings and Grounds Supervisor



Laboratory Report

Champlain Valley Edu Services 200674
1585 Military Turnpike
Plattsburgh, NY 12901

Atten: Stephanie Trombly

PROJECT: Lead in School Taps, CPCS
WORK ORDER: **1609-21940**
DATE RECEIVED: September 26, 2016
DATE REPORTED: October 11, 2016
SAMPLER: Caleb Spaulding

Enclosed please find the results of the analyses performed for the samples referenced on the attached chain of custody located at the end of this report.

The column labeled Lab/Tech in the accompanying report denotes the laboratory facility where the testing was performed and the technician who conducted the assay. A "W" designates the Williston, VT lab under NELAC certification ELAP 11263; "R" designates the Lebanon, NH facility under certification NH 2037 and "N" the Plattsburgh, NY lab under certification ELAP 11892. "Sub" indicates the testing was performed by a subcontracted laboratory. The accreditation status of the subcontracted lab is referenced in the corresponding NELAC and Qual fields.

This NELAC column also denotes the accreditation status of each laboratory for each reported parameter. "A" indicates the referenced laboratory is NELAC accredited for the parameter reported. "N" indicates the laboratory is not accredited. "U" indicates that NELAC does not offer accreditation for that parameter in that specific matrix. Test results denoted with an "A" meet all National Environmental Laboratory Accreditation Program requirements except where denoted by pertinent data qualifiers. Test results are representative of the samples as they were received at the laboratory.

Endyne, Inc. warrants, to the best of its knowledge and belief, the accuracy of the analytical test results contained in this report, but makes no other warranty, expressed or implied, especially no warranties of merchantability or fitness for a particular purpose.

Reviewed by:

Christina A Lafountain
Laboratory Director Plattsburgh, NY

Laboratory Report

CLIENT: Champlain Valley Edu Services
PROJECT: Lead in School Taps, CPCS

WORK ORDER: **1609-21940**
DATE RECEIVED: 9/26/16

001	Site: Front hall girls left sink	Stagnant:	8.10 Hrs	Date Sampled:	9/23/16	Time:	22:56
<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	0.0028	mg/L	SM 3113B-04	10/7/16	W MGT	A	
002	Site: Front Hall girls right sink	Stagnant:	8.10 Hrs	Date Sampled:	9/23/16	Time:	22:56
<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	0.0012	mg/L	SM 3113B-04	10/7/16	W MGT	A	
003	Site: Front hall girls water fountain	Stagnant:	8.12 Hrs	Date Sampled:	9/23/16	Time:	22:57
<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	< 0.0010	mg/L	SM 3113B-04	10/7/16	W MGT	A	
004	Site: Front hall girls water bottle fi	Stagnant:	8.10 Hrs	Date Sampled:	9/23/16	Time:	22:58
<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	< 0.0010	mg/L	SM 3113B-04	10/7/16	W MGT	A	
005	Site: Front hall boys water fountain	Stagnant:	8.20 Hrs	Date Sampled:	9/23/16	Time:	23:02
<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	< 0.0010	mg/L	SM 3113B-04	10/7/16	W MGT	A	
006	Site: front hall boys left sink	Stagnant:	8.15 Hrs	Date Sampled:	9/23/16	Time:	23:01
<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	0.0045	mg/L	SM 3113B-04	10/7/16	W MGT	A	
007	Site: front hall boys right sink	Stagnant:	8.15 Hrs	Date Sampled:	9/23/16	Time:	23:01
<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	0.0056	mg/L	SM 3113B-04	10/7/16	W MGT	A	
008	Site: Back hall boys left sink	Stagnant:	8.42 Hrs	Date Sampled:	9/23/16	Time:	23:03
<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	0.0028	mg/L	SM 3113B-04	10/7/16	W MGT	A	
009	Site: Back hall boys right sink	Stagnant:	8.43 Hrs	Date Sampled:	9/23/16	Time:	23:04
<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	< 0.0010	mg/L	SM 3113B-04	10/7/16	W MGT	A	
010	Site: back hall boys mop sink	Stagnant:	8.43 Hrs	Date Sampled:	9/23/16	Time:	23:04
<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>

Laboratory Report

CLIENT: Champlain Valley Edu Services	WORK ORDER: 1609-21940
PROJECT: Lead in School Taps, CPCS	DATE RECEIVED: 9/26/16
Lead, Total 0.0024 mg/L SM 3113B-04	10/7/16 W MGT A

011	Site: back hall girls left sink	Stagnant:	8.32 Hrs	Date Sampled:	9/23/16	Time: 23:05
-----	---------------------------------	-----------	----------	---------------	---------	-------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	0.0013	mg/L	SM 3113B-04	10/7/16	W MGT	A	

012	Site: back hall girls right sink	Stagnant:	8.32 Hrs	Date Sampled:	9/23/16	Time: 23:05
-----	----------------------------------	-----------	----------	---------------	---------	-------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	0.0014	mg/L	SM 3113B-04	10/7/16	W MGT	A	

013	Site: Nurse's bathroom sink	Stagnant:	8.70 Hrs	Date Sampled:	9/23/16	Time: 23:07
-----	-----------------------------	-----------	----------	---------------	---------	-------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	0.0014	mg/L	SM 3113B-04	10/7/16	W MGT	A	

014	Site: Nurse's office sink	Stagnant:	8.70 Hrs	Date Sampled:	9/23/16	Time: 23:07
-----	---------------------------	-----------	----------	---------------	---------	-------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	< 0.0010	mg/L	SM 3113B-04	10/7/16	W MGT	A	

015	Site: Upstairs boys left side sink	Stagnant:	8.40 Hrs	Date Sampled:	9/23/16	Time: 23:09
-----	------------------------------------	-----------	----------	---------------	---------	-------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	0.0050	mg/L	SM 3113B-04	10/7/16	W MGT	A	

016	Site: Upstairs boys right side sink	Stagnant:	8.40 Hrs	Date Sampled:	9/23/16	Time: 23:09
-----	-------------------------------------	-----------	----------	---------------	---------	-------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	0.0051	mg/L	SM 3113B-04	10/7/16	W MGT	A	

017	Site: Science room 206	Stagnant:	8.72 Hrs	Date Sampled:	9/23/16	Time: 23:08
-----	------------------------	-----------	----------	---------------	---------	-------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	< 0.0010	mg/L	SM 3113B-04	10/7/16	W MGT	A	

018	Site: Upstairs hall fountain	Stagnant:	8.73 Hrs	Date Sampled:	9/23/16	Time: 23:09
-----	------------------------------	-----------	----------	---------------	---------	-------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	< 0.0010	mg/L	SM 3113B-04	10/7/16	W MGT	A	

019	Site: Upstairs staff bathroom	Stagnant:	8.77 Hrs	Date Sampled:	9/23/16	Time: 23:16
-----	-------------------------------	-----------	----------	---------------	---------	-------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	< 0.0010	mg/L	SM 3113B-04	10/7/16	W MGT	A	

Laboratory Report

CLIENT: Champlain Valley Edu Services
PROJECT: Lead in School Taps, CPCS

WORK ORDER: 1609-21940
DATE RECEIVED: 9/26/16

020 Site: Upstairs girls left sink Stagnant: 8.87 Hrs Date Sampled: 9/23/16 Time: 23:17

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.0068	mg/L	SM 3113B-04	10/7/16	W MGT	A	

021 Site: Upstairs girls right sink Stagnant: 8.87 Hrs Date Sampled: 9/23/16 Time: 23:17

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.0078	mg/L	SM 3113B-04	10/7/16	W MGT	A	

022 Site: Family consumer washer sink Stagnant: 8.87 Hrs Date Sampled: 9/23/16 Time: 23:19

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.0063	mg/L	SM 3113B-04	10/7/16	W MGT	A	

023 Site: Family consumer L counter sink Stagnant: 8.87 Hrs Date Sampled: 9/23/16 Time: 23:19

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.0042	mg/L	SM 3113B-04	10/7/16	W MGT	A	

024 Site: Family consumer R counter sink Stagnant: 8.90 Hrs Date Sampled: 9/23/16 Time: 23:20

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.0070	mg/L	SM 3113B-04	10/7/16	W MGT	A	

025 Site: Coaches room (Swinton) Stagnant: 9.45 Hrs Date Sampled: 9/23/16 Time: 23:23

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	SM 3113B-04	10/7/16	W MGT	A	

026 Site: Boys locker fountain Stagnant: 9.47 Hrs Date Sampled: 9/23/16 Time: 23:23

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	SM 3113B-04	10/7/16	W MGT	A	

027 Site: Boys locker bathroom sink Stagnant: 9.48 Hrs Date Sampled: 9/23/16 Time: 23:24

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	SM 3113B-04	10/7/16	W MGT	A	

028 Site: Gym hall boys left sink Stagnant: 8.85 Hrs Date Sampled: 9/23/16 Time: 23:26

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.0065	mg/L	SM 3113B-04	10/7/16	W MGT	A	

029 Site: Gym hall boys right sink Stagnant: 8.85 Hrs Date Sampled: 9/23/16 Time: 23:26

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
-----------	--------	-------	--------	---------------	----------	-------	-------

Laboratory Report

CLIENT: Champlain Valley Edu Services	WORK ORDER: 1609-21940
PROJECT: Lead in School Taps, CPCS	DATE RECEIVED: 9/26/16
Lead, Total 0.0035 mg/L SM 3113B-04	10/7/16 W MGT A

030	Site: Gym hall fountain	Stagnant: 8.93 Hrs	Date Sampled: 9/23/16	Time: 23:27
-----	-------------------------	--------------------	-----------------------	-------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	< 0.0010	mg/L	SM 3113B-04	10/7/16	W MGT	A	

031	Site: Gym hall bottle fill	Stagnant: 8.93 Hrs	Date Sampled: 9/23/16	Time: 23:27
-----	----------------------------	--------------------	-----------------------	-------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	< 0.0010	mg/L	SM 3113B-04	10/7/16	W MGT	A	

032	Site: Gym hall girls left sink	Stagnant: 8.93 Hrs	Date Sampled: 9/23/16	Time: 23:29
-----	--------------------------------	--------------------	-----------------------	-------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	0.0035	mg/L	SM 3113B-04	10/7/16	W MGT	A	

033	Site: Gym hall girls right sink	Stagnant: 8.93 Hrs	Date Sampled: 9/23/16	Time: 23:29
-----	---------------------------------	--------------------	-----------------------	-------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	0.0086	mg/L	SM 3113B-04	10/7/16	W MGT	A	

034	Site: Coaches room (McGuiness)	Stagnant: 8.95 Hrs	Date Sampled: 9/23/16	Time: 23:29
-----	--------------------------------	--------------------	-----------------------	-------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	< 0.0010	mg/L	SM 3113B-04	10/7/16	W MGT	A	

035	Site: Girls locker sink	Stagnant: 8.95 Hrs	Date Sampled: 9/23/16	Time: 23:32
-----	-------------------------	--------------------	-----------------------	-------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	0.0026	mg/L	SM 3113B-04	10/7/16	W MGT	A	

036	Site: Girls locker fountain	Stagnant: 8.97 Hrs	Date Sampled: 9/23/16	Time: 23:33
-----	-----------------------------	--------------------	-----------------------	-------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	0.0152	mg/L	SM 3113B-04	10/7/16	W MGT	A	

037	Site: Kitchen Steam Kettle	Stagnant: 9.10 Hrs	Date Sampled: 9/23/16	Time: 22:46
-----	----------------------------	--------------------	-----------------------	-------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	< 0.0010	mg/L	SM 3113B-04	10/7/16	W MGT	A	

038	Site: Kitchen island sink	Stagnant: 9.40 Hrs	Date Sampled: 9/23/16	Time: 22:50
-----	---------------------------	--------------------	-----------------------	-------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	0.0031	mg/L	SM 3113B-04	10/7/16	W MGT	A	

Laboratory Report

CLIENT: Champlain Valley Edu Services
PROJECT: Lead in School Taps, CPCS

WORK ORDER: 1609-21940
DATE RECEIVED: 9/26/16

039 Site: Kitchen back room sink Stagnant: 9.43 Hrs Date Sampled: 9/23/16 Time: 22:51

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	SM 3113B-04	10/7/16	W MGT	A	

040 Site: Kitchen ice maker Stagnant: 9.47 Hrs Date Sampled: 9/24/16 Time: 0:13

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	SM 3113B-04	10/7/16	W MGT	A	

041 Site: Kitchen 3 bay left side Stagnant: 8.77 Hrs Date Sampled: 9/23/16 Time: 22:51

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.0042	mg/L	SM 3113B-04	10/7/16	W MGT	A	

042 Site: Kitchen 3 bay middle Stagnant: 9.53 Hrs Date Sampled: 9/23/16 Time: 22:52

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.201	mg/L	SM 3113B-04	10/8/16	W RJL	A	

043 Site: Kitchen 3 bay right side Stagnant: 9.55 Hrs Date Sampled: 9/23/16 Time: 22:53

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.0035	mg/L	SM 3113B-04	10/7/16	W MGT	A	

044 Site: Cafeteria fountain Stagnant: 8.90 Hrs Date Sampled: 9/23/16 Time: 23:40

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	SM 3113B-04	10/7/16	W MGT	A	

045 Site: Cafeteria bottle fill Stagnant: 8.90 Hrs Date Sampled: 9/23/16 Time: 23:40

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	SM 3113B-04	10/7/16	W MGT	A	

046 Site: 6th grade 113 Stagnant: 9.18 Hrs Date Sampled: 9/23/16 Time: 23:41

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	SM 3113B-04	10/7/16	W MGT	A	

047 Site: 5th grade 114 Stagnant: 9.22 Hrs Date Sampled: 9/23/16 Time: 23:43

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	SM 3113B-04	10/7/16	W MGT	A	

048 Site: 60' hall bathroom Stagnant: 9.15 Hrs Date Sampled: 9/23/16 Time: 23:43

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
-----------	--------	-------	--------	---------------	----------	-------	-------

Laboratory Report

CLIENT: Champlain Valley Edu Services	WORK ORDER: 1609-21940
PROJECT: Lead in School Taps, CPCS	DATE RECEIVED: 9/26/16
Lead, Total 0.0176 mg/L SM 3113B-04	10/7/16 W MGT A

049 Site: 4th grade 115	Stagnant:	9.58 Hrs	Date Sampled:	9/23/16	Time: 23:45
-------------------------	-----------	----------	---------------	---------	-------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	0.0035	mg/L	SM 3113B-04	10/7/16	W MGT	A	

050 Site: Read comp lab 116	Stagnant:	9.42 Hrs	Date Sampled:	9/23/16	Time: 23:45
-----------------------------	-----------	----------	---------------	---------	-------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	0.0012	mg/L	SM 3113B-04	10/7/16	W MGT	A	

051 Site: Technology 117	Stagnant:	9.28 Hrs	Date Sampled:	9/23/16	Time: 23:47
--------------------------	-----------	----------	---------------	---------	-------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	0.0058	mg/L	SM 3113B-04	10/7/16	W MGT	A	

052 Site: Art 120	Stagnant:	9.20 Hrs	Date Sampled:	9/23/16	Time: 23:47
-------------------	-----------	----------	---------------	---------	-------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	< 0.0010	mg/L	SM 3113B-04	10/7/16	W MGT	A	

053 Site: Music hall staff bath	Stagnant:	9.40 Hrs	Date Sampled:	9/23/16	Time: 23:49
---------------------------------	-----------	----------	---------------	---------	-------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	< 0.0010	mg/L	SM 3113B-04	10/7/16	W MGT	A	

054 Site: Music 126	Stagnant:	9.43 Hrs	Date Sampled:	9/23/16	Time: 23:49
---------------------	-----------	----------	---------------	---------	-------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	< 0.0010	mg/L	SM 3113B-04	10/7/16	W MGT	A	

055 Site: Resource room Bathroom 124	Stagnant:	9.53 Hrs	Date Sampled:	9/23/16	Time: 23:51
--------------------------------------	-----------	----------	---------------	---------	-------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	< 0.0010	mg/L	SM 3113B-04	10/7/16	W MGT	A	

056 Site: Resource room classroom 126	Stagnant:	9.53 Hrs	Date Sampled:	9/23/16	Time: 23:51
---------------------------------------	-----------	----------	---------------	---------	-------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	0.0012	mg/L	SM 3113B-04	10/8/16	W MGT	A	

057 Site: Pre K bathroom	Stagnant:	9.63 Hrs	Date Sampled:	9/23/16	Time: 23:53
--------------------------	-----------	----------	---------------	---------	-------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	< 0.0010	mg/L	SM 3113B-04	10/8/16	W MGT	A	

Laboratory Report

CLIENT: Champlain Valley Edu Services
PROJECT: Lead in School Taps, CPCS

WORK ORDER: **1609-21940**
DATE RECEIVED: 9/26/16

058 Site: Pre K 123 classroom Stagnant: 9.63 Hrs Date Sampled: 9/23/16 Time: 23:53

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	SM 3113B-04	10/8/16	W MGT	A	

059 Site: Kindergarden bathroom Stagnant: 9.40 Hrs Date Sampled: 9/23/16 Time: 23:53

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.0010	mg/L	SM 3113B-04	10/8/16	W MGT	A	

060 Site: Kindergarden classroom 122 Stagnant: 9.40 Hrs Date Sampled: 9/23/16 Time: 23:53

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	SM 3113B-04	10/8/16	W MGT	A	

061 Site: Red end boys L sink Stagnant: 9.27 Hrs Date Sampled: 9/23/16 Time: 23:56

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	SM 3113B-04	10/8/16	W MGT	A	

062 Site: Red end boys middle sink Stagnant: 9.27 Hrs Date Sampled: 9/23/16 Time: 23:56

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.0030	mg/L	SM 3113B-04	10/8/16	W MGT	A	

063 Site: Red end boys R sink Stagnant: 9.27 Hrs Date Sampled: 9/23/16 Time: 23:56

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.0022	mg/L	SM 3113B-04	10/8/16	W MGT	A	

064 Site: Red end hall fountain Stagnant: 9.20 Hrs Date Sampled: 9/23/16 Time: 23:56

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	SM 3113B-04	10/8/16	W MGT	A	

065 Site: Red end hall bottle fill Stagnant: 9.20 Hrs Date Sampled: 9/23/16 Time: 23:56

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	SM 3113B-04	10/8/16	W MGT	A	

066 Site: Red end girls L sink Stagnant: 9.25 Hrs Date Sampled: 9/23/16 Time: 23:58

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	SM 3113B-04	10/8/16	W MGT	A	

067 Site: Red end girls middle sink Stagnant: 9.25 Hrs Date Sampled: 9/23/16 Time: 23:58

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
-----------	--------	-------	--------	---------------	----------	-------	-------

Laboratory Report

CLIENT:	Champlain Valley Edu Services	WORK ORDER:	1609-21940
PROJECT:	Lead in School Taps, CPCS	DATE RECEIVED:	9/26/16
Lead, Total	0.0021	mg/L	SM 3113B-04
			10/8/16
			W MGT
			A

068	Site: Red end girls R sink	Stagnant:	9.27 Hrs	Date Sampled:	9/23/16	Time:	23:59
-----	----------------------------	-----------	----------	---------------	---------	-------	-------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	< 0.0010	mg/L	SM 3113B-04	10/8/16	W MGT	A	

069	Site: Red end boys single	Stagnant:	9.23 Hrs	Date Sampled:	9/24/16	Time:	0:00
-----	---------------------------	-----------	----------	---------------	---------	-------	------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	< 0.0010	mg/L	SM 3113B-04	10/8/16	W MGT	A	

070	Site: Red end girls single	Stagnant:	9.25 Hrs	Date Sampled:	9/24/16	Time:	0:01
-----	----------------------------	-----------	----------	---------------	---------	-------	------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	< 0.0010	mg/L	SM 3113B-04	10/8/16	W MGT	A	

071	Site: Front hall break room	Stagnant:	9.48 Hrs	Date Sampled:	9/24/16	Time:	0:15
-----	-----------------------------	-----------	----------	---------------	---------	-------	------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	< 0.0010	mg/L	SM 3113B-04	10/8/16	W MGT	A	

072	Site: Back of bus garage south end	Stagnant:	9.58 Hrs	Date Sampled:	9/24/16	Time:	0:05
-----	------------------------------------	-----------	----------	---------------	---------	-------	------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	0.0045	mg/L	SM 3113B-04	10/8/16	W MGT	A	

073	Site: Edge of wood	Stagnant:	0.00 Hrs	Date Sampled:	9/24/16	Time:	0:07
-----	--------------------	-----------	----------	---------------	---------	-------	------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	0.0020	mg/L	SM 3113B-04	10/8/16	W MGT	A	

074	Site: Home Dugout	Stagnant:	0.00 Hrs	Date Sampled:	9/24/16	Time:	0:08
-----	-------------------	-----------	----------	---------------	---------	-------	------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	0.0242	mg/L	SM 3113B-04	10/8/16	W MGT	A	

075	Site: Maint Office	Stagnant:	0.00 Hrs	Date Sampled:	9/24/16	Time:	0:16
-----	--------------------	-----------	----------	---------------	---------	-------	------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	0.0016	mg/L	SM 3113B-04	10/8/16	W MGT	A	

Test results comply with all NELAC requirements unless otherwise noted. This Laboratory Report includes the client's COC sample documentation and shall not be reproduced except in full, without written approval of the laboratory.

Endyne, Inc. - Plattsburgh Lab

LAB USE ONLY
Due Date: 260416

315 New York Road
Plattsburgh, NY 12903
Phone (518)563-1720

Fax (518)563-0052
info@endynelabs.com
ELAP #11892

Crown Pt School

Client: Champlain Valley ED Account #: 200674

Email Address: _____

Contact Person: Caleb Spaulding Project Name: BOXES

Phone: (518) 597-3285 3T - Lead In Schools

PO # _____

SAMPLE SUPPLY INFORMATION

PWS # Crown Point WD

Collection Address: Crown Point Central

2758 Main Street

City: Crown Point State: NY Zip: 12928

Pag 1 of 3 Collector's Name: Caleb Spaulding

SAMPLE MATRIX CODES		Compliance? Yes Initial Testing or Repeat Testing	Bottle Type / Volume	M a t r i x	Preservation	First Draw (Y)	Flushed Line (Y)	Total Lead	Analysis Requested:		Lab Use Sample #
DW=drinking water	SW=Surface Water								Water Last Used (Date / Time)		
WWW=waste water	SD=solid										
MW=monitoring well	SO=soil										
HW=hazardous waste	SL=sediment										
TURNAROUND TIME REQUESTED											
Standard (2-4 weeks)											
Sample ID / Collection Site	Date/Time										
1 Front Hall Girls Left Sink	9/23/16 10:56 ^{am}	250mL, P	DW	*	Y	N	X			9/23/16 2:50 ^{pm}	001
2 Front Hall Girls Right Sink	10:56 Pm	250mL, P	DW	*			X			2:50 Pm	002
3 Front Hall Girls water fountain	10:57 Pm	250mL, P	DW	*			X			2:50 Pm	003
4 Front Hall Girls water Bottle fill	10:58 Pm	250mL, P	DW	*			X			2:52 Pm	004
5 Front Hall Boys water fountain	11:02 Pm	250mL, P	DW	*			X			2:50 Pm	005
6 Front Hall Boys Left Sink	11:01 Pm	250mL, P	DW	*			X			2:52 Pm	006
7 Front Hall Boys Right Sink	11:01 Pm	250mL, P	DW	*			X			2:52 Pm	007
8 Back Hall Boys Left Sink	11:03 Pm	250mL, P	DW	*			X			2:38 Pm	008
9 Back Hall Boys Right Sink	11:04 Pm	250mL, P	DW	*			X			2:38 Pm	009
10 Back Hall Boys mop sink	11:04 Pm	250mL, P	DW	*			X			2:38 Pm	010
11 Back Hall Girls Left Sink	11:05 Pm	250mL, P	DW	*			X			2:46 Pm	011
12 Back Hall Girls Right Sink	11:05 Pm	250mL, P	DW	*	Y	Y	X			2:46 Pm	012

SAMPLE RECEIPT (Lab Use Only)		Date	Time	Sample Relinquished By (SIGN HERE)	Samples Received By
Samples intact?	yes	26 Sep 16	1125	<i>[Signature]</i>	<i>[Signature]</i>
Filled to proper volume?	yes				
# of Containers	75				



* Samples preserved with NHO3 to pH < 2 after receipt at the lab.

@ ~100 on 27 Sep 16 by Chris L. (S)

Note: Results are emailed to the Health Department at the same time as the client unless otherwise noted on the COC.

1609-21940



Champlain Valley Edu Services
Lead in School Taps, CPCS

OFFICE USE ONLY

Analysis Fee \$ _____ of A/R

Terms are net 30 days v

Payment Method Cash Check

Endyne, Inc. - Plattsburgh Lab

LAB USE ONLY
Due Date:

315 New York Road
Plattsburgh, NY 12903
Phone (518)563-1720

Fax (518)563-0052
info@endynelabs.com
ELAP #11892

Client: Champlain Valley ES Account #: 200674 Collector's Name: Caleb Spaulding
CPCS Page 2 of 3 Work Order # 21940

Sample ID / Collection Site	Date/Time	Bottle	M a t r i x	P r e s	1st Draw	Flushed Line	Lead, Total	Water Last Used (date/Time)	Sample #
13 Nurse's Bathroom Sink	9/23/16 11:07pm	250mL, P	DW	*	Y	N	X	9/23/16 2:25pm	013
14 Nurse's Office Sink	11:07pm	250mL, P	DW	*			X	2:25pm	014
15 Upstairs Boys Left side Sink	11:09pm	250mL, P	DW	*			X	2:45pm	015
16 Upstairs Boys Right side Sink	11:09pm	250mL, P	DW	*			X	2:45pm	016
17 Science Room 206	11:08pm	250mL, P	DW	*			X	2:25pm	017
18 Upstairs Hall fountain	11:09pm	250mL, P	DW	*			X	2:25pm	018
19 Upstairs Staff Bathroom	11:16pm	250mL, P	DW	*			X	2:30pm	019
20 Upstairs Girls Left Sink	11:17pm	250mL, P	DW	*			X	2:25pm	020
21 Upstairs Girls Right Sink	11:17pm	250mL, P	DW	*			X	2:25pm	021
22 Family Consumer Washer Sink	11:19pm	250mL, P	DW	*			X	2:27pm	022
23 Family Consumer Left Counter Sink	11:19pm	250mL, P	DW	*			X	2:27pm	023
24 Family Consumer Right Counter Sink	11:20pm	250mL, P	DW	*			X	2:26pm	024
25 Coaches Room (Swinton)	11:23pm	250mL, P	DW	*			X	1:56pm	025
26 Boys Locker fountain	11:23pm	250mL, P	DW	*			X	1:55pm	026
27 Boys Locker Bathroom Sink	11:24pm	250mL, P	DW	*			X	1:55pm	027
28 Gym Hall Boys Left Sink	11:26pm	250mL, P	DW	*			X	2:35pm	028
29 Gym Hall Boys Right Sink	11:26pm	250mL, P	DW	*			X	2:35pm	029
30 Gym Hall fountain	11:27pm	250mL, P	DW	*			X	2:31pm	030
31 Gym Hall Bottle fill	11:27pm	250mL, P	DW	*			X	2:31pm	031
32 Gym Hall Girls Left Sink	11:29pm	250mL, P	DW	*			X	2:33pm	032
33 Gym Hall Girls Right Sink	11:29pm	250mL, P	DW	*			X	2:33pm	033
34 Coaches Room (McGuinness)	11:29pm	250mL, P	DW	*			X	2:32pm	034
35 Girls Locker Sink	11:32pm	250mL, P	DW	*			X	2:35pm	035
36 Girls Locker fountain	11:33pm	250mL, P	DW	*			X	2:35pm	036
37 Kitchen Steam Kettle	10:46pm	250mL, P	DW	*			X	1:40pm	037
38 Kitchen Island Sink	10:50pm	250mL, P	DW	*			X	1:26pm	038
39 Kitchen Back room sink	10:51pm	250mL, P	DW	*			X	1:25pm	039
40 Kitchen Ice maker	9/24 12:13am	250mL, P	DW	*			X	2:45pm	040
41 Kitchen 3bay Left side	9/23 10:51pm	250mL, P	DW	*			X	2:05pm	041
42 Kitchen 3bay middle	10:52pm	250mL, P	DW	*			X	1:20pm	042
43 Kitchen 3bay Right side	10:53pm	250mL, P	DW	*			X	1:20pm	043
44 Cafeteria fountain	11:40pm	250mL, P	DW	*			X	2:46pm	044
45 Cafeteria Bottle fill	11:40pm	250mL, P	DW	*			X	2:46pm	045
46 6 th Grade 113	9/24 11:41am	250mL, P	DW	*	↓	↓	X	↓ 2:30pm	046

Endyne, Inc. - Plattsburgh Lab

LAB USE ONLY

Due Date:

315 New York Road
Plattsburgh, NY 12903
Phone (518)563-1720

Fax (518)563-0052
info@endynelabs.com
ELAP #11892

Client: Champlain Valley EB Account #: 200674 Collector's Name: Caleb Spaulding
CPCS

Page 3 of 3

Work Order # 21940

Sample ID / Collection Site	Date/Time	Bottle	M a t r i x	Pres	1st Draw	Flushed Line	Lead, Total	Water Last Used (date/Time)	Sample #
47 5 th Grade 114	9/23/16 11:43 AM	250mL, P	DW	*	Y	N	X	9/23/16 2:30 PM	047
48 60' Hall Bathroom	11:43 PM	250mL, P	DW	*			X	2:34 PM	048
49 4 th Grade 115	11:45 PM	250mL, P	DW	*			X	2:10 PM	049
50 Read Comp. Lab 116	11:45 PM	250mL, P	DW	*			X	2:20 PM	050
51 Technology 117	11:47 PM	250mL, P	DW	*			X	2:30 PM	051
52 Art 120	11:47 PM	250mL, P	DW	*			X	2:35 PM	052
53 Music Hall Staff Bath	11:49 PM	250mL, P	DW	*			X	2:25 PM	053
54 Music 126	11:49 PM	250mL, P	DW	*			X	2:23 PM	054
55 Resource Room ^{Bathroom} 124	11:51 PM	250mL, P	DW	*			X	2:19 PM	055
56 Resource Room ^{Classroom} 126	11:51 PM	250mL, P	DW	*			X	2:19 PM	056
57 Pre K Bathroom	11:53 PM	250mL, P	DW	*			X	2:15 PM	057
58 Pre K 123 Classroom	11:53 PM	250mL, P	DW	*			X	2:15 PM	058
59 Kindergarten Bathroom	11:53 PM	250mL, P	DW	*			X	2:29 PM	059
60 Kindergarten ^{Classroom} 122	11:53 PM	250mL, P	DW	*			X	2:29 PM	060
61 Red End Boys ^{Left} Sink	11:56 PM	250mL, P	DW	*			X	2:40 PM	061
62 Red End Boys ^{middle} sink	11:56 PM	250mL, P	DW	*			X	2:40 PM	062
63 Red End Boys ^{Right} sink	11:56 PM	250mL, P	DW	*			X	2:40 PM	063
64 Red End Hall Fountain	11:56 PM	250mL, P	DW	*			X	2:44 PM	064
65 Red End Hall Bottle fill	11:56 PM	250mL, P	DW	*			X	2:44 PM	065
66 Red End Girls ^{Left} sink	11:58 PM	250mL, P	DW	*			X	2:43 PM	066
67 Red End Girls ^{middle} sink	11:58 PM	250mL, P	DW	*			X	2:43 PM	067
68 Red End Girls ^{Right} Sink	11:59 PM	250mL, P	DW	*			X	2:43 PM	068
69 Red End Boys Single	9/24 12:00 AM	250mL, P	DW	*			X	2:46 PM	069
70 Red End Girls Single	9/24 12:01 AM	250mL, P	DW	*			X	2:46 PM	070
71 Front Hall Break room	9/24 12:15 AM	250mL, P	DW	*			X	2:46 PM	071
72 Back of Bus garage ^{South End}	9/24 12:05 AM	250mL, P	DW	*			X	2:30 PM	072
73 Edge of wood	9/24 12:07 AM	250mL, P	DW	*			X	June 16	073
74 Home Dugout	1/24 12:08 AM	250mL, P	DW	*			X	June 16	074
75 Maint. Office	2/24 12:16 AM	250mL, P	DW	*			X	June 16	075
76		250mL, P	DW	*			X	2:54 PM	076
77		250mL, P	DW	*			X		077
78		250mL, P	DW	*			X		078
79		250mL, P	DW	*			X		079
80		250mL, P	DW	*	✓	✓	X		800